Easy mounting photoelectric sensor in short M18 housing

# E3FZ/E3FR


- Secure-click snap mounting for fast installation
- High power LED for enhanced sensing distance
- Short housing with less than
   40 mm length
- Minimal optical axis deviation for easy alignment



### **Features**


### Easy and fast installation

The **SecureClick** snap mounting mechanism provides easy installation in 2 steps and enhanced protection against vibration.



\*SecureClick has been tested to withstand severe vibrations.

Installation time can be reduced by up to 10 times compared to conventional sensors.



### **Ordering Information**

### Snap mounting – E3FZ<sup>\*2</sup>

Sensor type	Sensing distance	Connecti	on method			Order code	
		88		Щ		NPN output	PNP output
Through-beam	15 m	-	_	2 m	_*3	E3FZ-T61H 2M	E3FZ-T81H 2M
		-		_	_*3	E3FZ-T66H	E3FZ-T86H
Retroreflective with M.S.R.	0.1 to 4 m <sup>*1</sup>	_	_	2 m	_*3	E3FZ-R61H 2M	E3FZ-R81H 2M
		_		-	_*3	E3FZ-R66H	E3FZ-R86H
Diffuse reflective	1 m (adjustable)	_	_	2 m	_*3	E3FZ-D62 2M	E3FZ-D82 2M
		_		-	_*3	E3FZ-D67	E3FZ-D87
Diffuse reflective (background suppression)	100 mm (fixed)	_	_	2 m	_*3	E3FZ-LS61H 2M	E3FZ-LS81H 2M
		_		-	_*3	E3FZ-LS66H	E3FZ-LS86H
	200 mm (fixed)	_	_	2 m	_*3	E3FZ-LS64H 2M	E3FZ-LS84H 2M
		-		_	_*3	E3FZ-LS69H	E3FZ-LS89H

#### Radial mounting - E3FR

Sensor type	Sensing distance	Connecti	on method	I		Order code	
		000		Ш Ц		NPN output	PNP output
Through-beam	15 m	_	_	2 m	_*3	E3FR-T61H 2M	E3FR-T81H 2M
		_		-	_*3	E3FR-T66H	E3FR-T86H
Retroreflective with M.S.R.	0.1 to 4 m <sup>*1</sup>	_	_	2 m	_*3	E3FR-R61H 2M	E3FR-R81H 2M
		_		-	_*3	E3FR-R66H	E3FR-R86H
Diffuse reflective	1 m (adjustable)	_	_	2 m	_*3	E3FR-D62 2M	E3FR-D82 2M
		_		-	_*3	E3FR-D67	E3FR-D87
Diffuse reflective (background suppression)	100 mm (fixed)	_	-	2 m	_*3	E3FR-LS61H 2M	E3FR-LS81H 2M
		_		-	_*3	E3FR-LS66H	E3FR-LS86H
	200 mm (fixed)	_	_	2 m	_*3	E3FR-LS64H 2M	E3FR-LS84H 2M
		_		_	_*3	E3FR-LS69H	E3FR-LS89H

\*1. Measured with reflector E39-R1S

\*2.

The reflector is sold separately. Mounting with Snap-Holder (provided with product) or M18 Nuts (provided with product) possible. Pre-wired connectors are available on request (item description see "Model Number Legend" on page 4) \*3.

#### Accessories Reflectors

Shape	Туре	Material	Features	Size in mm	Applicable Sensor	Order code
	General purpose reflectors	- ABS base - Acrylic surface	Surface screw mounting (diagonal holes)	59.9x40.3x7.5	<ul> <li>Retroreflective photo electric sensors – non polarizing</li> <li>Retroreflective photo electric sensors –</li> </ul>	E39-R1S
E.			Snap mounting	dia 30 mm (reflector) dia 6.5 mm (snap mount)	polarizing (MSR)	E39-R49

### Mounting brackets

Shape	Туре	Material	Features	Applicable Sensor	Order code
Contraction of the second seco	General purpose mounting	stainless steel	Horizontal angle adjustment	E3FZ (dia 20mm snap holder)	E39-EL8
	Telescope mounting		3D rotation (fits to 12 mm mounting rod)		E39-EL9

#### Sensor I/O connectors

Straight		2 m	4-wire	PVC	XS2F-D421-D80-A
	and the second second			PUR	Y92E-M12PUR4S2M-L
		5 m		PVC	XS2F-D421-G80-A
				PUR	Y92E-M12PUR4S5M-L
L-shaped	-shaped	2 m		PVC	XS2F-D422-D80-A
				PUR	Y92E-M12PUR4A2M-L
		5 m		PVC	XS2F-D422-G80-A
				PUR	Y92E-M12PUR4A5M-L

Note: For the complete list of sensor I/O connectors refer to E26E Accessories datasheet.

### Model Number Legend

### 

e.g., E3FZ-T81H; short housing/ through-beam/PNP output/2 m cable/without an adjustor/L-on/D-on by wire/ E3FZ-T86H-D; short housing/through-beam/PNP output/M12 connector/without an adjustor/L-on/D-on by wire/receiver E3FR-LS86; radial housing/background-suppression/PNP output/M12 connector/sensing distance of 100 mm/without an adjustor/ L-on/D-on by wire/

- 1. Cylindrical family name: E3F
- 2. Series name
  - 2: standard housing (seperate naming rule)
  - Z: short housing
  - R: radial housing
- 3. Sensing method
  - T: through-beam
  - R: retroreflective
  - D: diffuse reflective
  - LS: background suppression
- 4. Output
  - 6: NPN output
  - 8: PNP output
- 5. Connection
  - Through-beam, retroreflective types
    - 1: 2 m cable
  - 6: M12 connector
  - Diffuse reflective types
    - 2: 2 m cable
    - 7: M12 connector
  - Background suppression types
    - 1: 2 m cable/sensing distance of 100 mm
    - 4: 2 m cable/sensing distance of 200 mm
    - 6: M12 connector/sensing distance of 100 mm
    - 9: M12 connector/sensing distance of 200 mm

- 6. Adjuster
  - Blank: with volume adjuster/L-on/D-on by wire H: without volume adjuster/L-on/D-on by wire
- 7. Emitter/ Receiver
  - L: emitter
  - D: receiver
- 8. Kind of connection
  - Blank: standard 2 m cable or M12 connector
  - M1J: pre-wired with 30 cm cable and
    - M12 plug connector (4 pin)
  - M3J: pre-wired with 30 cm cable and M8 plug connector (4 pin)
  - M5J: pre-wired with 30 cm cable and M8 plug connector (3 pin)
  - M1TJ: pre-wired with 30cm cable and Twist&Click M12 plug connector (4 pin)
- 9. Cable length

Blank: M12 connector Number: cable length

### Mounting and dismounting

Mounting Step 1



Insert the snap holder into the mounting hole from the front


Step 2




Insert the sensor into the snap holder from the back








Verify the correct position (a clicking sound can be heard)




Verify the correct position (a clicking sound can be heard)

Dismounting

Step 1




Apply soft pressure to the sensor lens in the indicated areas (e.g. with two thumbs)




Remove the sensor

Step 2



Press down both snap-fits and push the snap holder forward.



Remove the snap holder



### Specifications

Item		Through-beam	Retroreflective	Diffuse reflective			
		E3FZ-T / E3FR-T	E3FZ-R / E3FR-R	E3FZ-D / E3FR-D			
Sensing distanc	e	15 m	4 m [100 mm]	1 m (white paper 300x300 mm)			
Spot diameter		-					
Standard sensir	ng object	Opaque: 12 mm dia .min	Opaque: 75 mm dia. min	-			
Differential trave	el	-		20% max. of sensing distance max.			
Black/white erro	or	-					
Directional angle	e	Emitter and Reciever: 3° to 15°	Emitter and Reciever: 3° to 15° Sensor: 3° to 10°, Reflector: 30° –				
Light source (wa	ave length)	Infrared LED (870 nm)	Red LED (660 nm)	Infrared LED (860 nm)			
Power supply vo	oltage	10 to 30 VDC, including 10% ripp	ble(p-p)				
Current consum	iption	45mA max. (Emitter: 25mA max., Receiver; 20 mA max. )	25 mA max.				
Control output		Light-on/Dark-on selectable by w	Load power supply voltage; 30 VDC max., Load current; 100 mA max.(Residual voltage; 2 V max.), Light-on/Dark-on selectable by wire, E3FI-6[]: NPN open-collector output E3FI-8[]: PNP open-collector output				
Protective circui	its	Power supply reverse polarity protection, output short-circuit protection, and reversed output polarity protection	ection, output short-circuit output short-circuit protection, mutual interference prevention and reversed output reversed output polarity protection				
Response time		Operate and reset; 1 ms max.					
Sensitivity adjust	stment	-	One-turn adjuster				
Ambient illumina (receiver side)	ation	Incandescent lamp; 3000 lx max., Sunlight 10000 lx max.					
Ambient temper	ature	Operating; -25 to +55°C, Storage; -40 to +70°C (with no icing or condensation)					
Ambient humidi	ty	Operating; 35 to 85% RH, Storage; 35 to 95% RH (with no condensation)					
Insulation resist	ance	20MΩ min. at 500 VDC					
Dielectric resista	ance	1000 VAC at 50/60 Hz for 1 min					
Vibration resista	ance	Destruction; 10 to 55 Hz, 1.5 mm double amplitude for 2 hours, each in X, Y and Z directions					
Shock resistance	e	Destruction; 500 m/s <sup>2</sup> , 3 times, each in X, Y and Z directions					
Degree of prote	ction *1	IEC 60529 IP67, IP69K after DIN 40050-9					
Connection met	hod	Pre-wired cable (standard length 2 m), Standard M12 connector					
Indicator		Operation indicator: yellow, stability indicator: green (Emitter has only power supply indicator; green)					
Weight	Pre-wired	approx. 120 g	approx. 60 g				
(packed state)	Standard connector	approx. 40 g approx. 20 g					
Material	Case	ABS					
	Cover lens Plate window	РММА					
Accessories	1	Instruction sheet, 2x M18 nuts, s	nap mounting tool (E3FZ only).				
The IP69k test	according to DIN 40	050 part 9 is intended to simulate high pr	essure/steam cleaning. During the test 14	-16 l/min water			

The IP69k test according to DIN 40 050 part 9 is intended to simulate high pressure/steam cleaning. During the test 14-16 l/min water at 80°C is sprayed onto the sensor from different angles with 8000-10000 kPa. The sensor may not suffer any damaging effects from high pressure water in appearance and functionality.



### Specification


Item		Background suppression (BGS)						
		E3FZ-LSD1H/E3FR-LSD1H	E3FZ-LS□4H / E3FR-LS□4H					
		E3FZ-LSD6H / E3FR-LSD6H	E3FZ-LS□9H / E3FR-LS□9H					
Sensing distance	e	10 to 100 mm (White paper 100x100 mm)	10 to 200 mm (White paper 100x100 mm)					
Spot diameter		4 mm dia. at sensing distance of 100 mm	18 mm dia. at sensing distance of 200 mm					
Standard sensir	ng object							
Differential trave	əl	3% of sensing distance max.	20% of sensing distance max.					
Black/white erro	or	5% of sensing distance max.	20% of sensing distance max.					
Directional angl	e	-						
Light source (wa	ave length)	Red LED (650 nm)	Red LED (660 nm)					
Power supply ve	oltage	10 to 30 VDC, including 10% ripple(p-p)						
Current consum	ption	25 mA max.						
Control output		Load power supply voltage; 30 VDC max., Load current; 100 mA max. (Residual voltage; 2 V max.), Light-on/Dark-on selectable by wire, E3F□-LS6: NPN open-collector output E3F□-LS8: PNP open-collector output						
Protective circu	its	Power supply reverse polarity protection, output short-circuit protection, mutual interference prevention and reversed output polarity protection						
Response time		Operate and reset; 1 ms max.						
Sensitivity adjust	stment	-						
Ambient illumina (receiver side)	ation	Incandescent lamp; 3000 lx max., Sunlight 10000 lx max.						
Ambient temper	rature	Operating; -25 to +55°C, Storage; -40 to +70°C (with no icing or condensation)						
Ambient humidi	ty	Operating; 35 to 85%RH, Storage; 35 to 95%RH (with no condensation)						
Insulation resist	ance	20MΩ min. at 500 VDC						
Dielectric resista	ance	1000 VAC at 50/60 Hz for 1 min						
Vibration resista	ance	Destruction; 10 to 55 Hz, 1.5 mm double amplitude for 2 hours, each in X, Y and Z directions						
Shock resistance	e	Destruction; 500m/s <sup>2</sup> , 3 times, each in X, Y and Z directions						
Degree of prote	ction *1	IEC 60529 IP67, IP69K after DIN 40050-9						
Connection met	hod	Pre-wired cable (standard length 2m), Standard M12 connector						
Indicator		Operation indicator: yellow, stability indicator: green						
Weight	Pre-wired	approx.60g						
(packed state)	Standard connector	approx.20g						
Material	Case	ABS						
Cover-lens Plate-window		PMMA						
Accessories	1	Instruction sheet, 2x M18 nuts, snap mounting	tool (E2EZ only)					

The IP69k test according to DIN 40 050 part 9 is intended to simulate high pressure/steam cleaning. During the test 14-16 l/min water at 80°C is sprayed onto the sensor from different angles with 8000-10000 kPa. The sensor may not suffer any damaging effects from high pressure water in appearance and functionality.




### Engineering Data (typical)

#### Parallel Operating Range Through-beam Models




**Retroreflective Models** 



#### **Operating Range**

Diffuse reflective Models E3F□-D□2(D□7)



(mm)

Distance Y

**BGS Models** 

-4 100 0 20 40 60 80 100 Distance X (mm)

-[


. Y


Х

†.

E3F□-LS□1H(LS□6H), left to right

Sensing object: 100 x 100 white paper







#### Excess Gain vs. Distance

Through-beam Models


E3FO-TO1H(TO6H)




#### **Retroreflective Models** E3F□-R□1H(R□6H)




#### Diffuse reflective Models E3F - D 2(D 7)



### Sensing Object Size vs. Distance




#### Spot Diameter vs. Distance




#### E3F□-LS□4H(LS□9H) Ê 20 18 Spot diameter 16 14 12 10 8 6 2 0L 0 50 100 150 250 200 Distance (mm)

# Sensing Distance vs. Sensing Object Material BGS Models



#### Inclination Characteristics (Horizontal) BGS Models

#### E3F -LS 1H(LS 6H)



#### E3F -LS 4H(LS 9H)

E3F -LS 4H(LS 9H)

250

200

150

100


50

0

White

paper

Sensing distance (mm)




Veneer Card- Black Black SUS

board paper rubber


Mirror

surface Material



#### Inclination Characteristics (Vertical) BGS Models

#### E3F□-LS□1H(LS□6H)



### Output Circuit Diagram

### PNP Output

Model	Operation mode	Timing charts	Mode selector switch	Output circuit
E3F□-T8 E3F□-R8 E3F□-D8	Light ON Dark ON	Light Incident Light Interrupted Operation indicator ON (yellow) OFF Output transistor ON OFF Load Operate (e.g., relay) Reset (Between brown and black wires)	Connect the pink wire (Pin(2)) to the brown (Pin(1)) or open the pink wire (Pin(2). Connect the	Through-beam Receivers, retroreflective models, diffuse reflective models Operation (Yellow) Stability (Green) ZD Black
		Light Interrupted Operation indicator ON (yellow) OFF Output transistor ON OFF Load Operate (e.g., relay) Reset (Between brown and black wires)	pink wire (Pin(2)) to the blue (Pin(3)).	Photo- electric Sensor Main Circuit Photo- (Control output) 3 Blue 0 V
		Por	icator	Brown 10 to 30 VDC Blue
E3F□-LS8	Light ON	Operation indicator ON (yellow) OFF Output transistor ON Load Operate (e.g., relay) Operate (Between brown and black wires)	Connect the pink wire (Pin(2)) to the brown (Pin(1)) or open the pink wire (Pin(2).	Operation Stability indicator (Yellow) Photo- electric Second
	Dark ON	Operation indicator ON (yellow) OFF Output transistor ON Load OFF (e.g., relay) Reset (Between brown and black wires)	Connect the pink wire (Pin(2)) to the blue (Pin(3)).	Sensor Main Circuit Pink Pink

#### NPN Output

-				-
Model	Operation	Timing charts	Mode	Output circuit
	mode		selector	
			switch	
E3F□-T6 E3F□-R6 E3F□-D6	T6       Light ON       Light Incident       Connect the pink wire (2) to the blue wire (3) or leave open.         D6       Operation indicator ON (yellow)       OFF       Incident       Incident wire (2) to the blue wire (3) or leave open.         Load       Operate       Incident wire (2) to the blue wire (3) or leave open.       Incident wire (2) to the blue wire (3) or leave open.         Dark ON       Operate       Incident wire (2) to the blue wire (3) or leave open.		pink wire (2) to the blue wire (3) or leave open.	Through-beam receivers, retroreflective models, diffuse reflective models Operation ** Stability indicator (Yellow) ** IO to 30 VDC (Control 100 mA (Relay))
	Light Interrupted — Operation indicator ON (yellow) OFF Output transistor ON OFF Load Operate (g., relay) Reset (B	Light Interrupted Operation indicator ON (yellow) OFF Output transistor ON OFF Load Operate	pink wire (2) to the brown wire (1).	Photo- electric Main Circuit
		P	ower dicator rreen) Photo- electric Sensor Main Circuit	Brown 10 to 30 VDC Blue
E3F□-LS6	F□-LS6       Light ON       Operation indicator ON (yellow) OFF       NEAR FAR on the pink wire (2) to the blue wire (3) or leave open.         Output transistor       ON OFF       Operation indicator ON OFF       Image: Connect the pink wire (2) to the blue wire (3) or leave open.         Dark ON       Operation indicator ON (yellow) OFF       Image: Connect the pink wire (2) to the blue wire (3) or leave open.         Dark ON       Operation indicator ON (yellow) OFF       Image: Connect the pink wire (2) to the brown and black wires)         Dark ON       Operation indicator ON (yellow) OFF       Image: Connect the pink wire (2) to the brown wire (1).         Load (e.g., relay)       Operate (Between brown and black wires)       Connect the pink wire (1).	Operation indicator (Vellow) Photo- electric Gargen) Brown 10 to 30 VDC (Green) Load Relazy Black 100 mA max.		
		(Control output)		

#### **Connector Pin Arrangement**

M12 Pre-wired Connector (-M1J) M12 Connector Pin Arrangement




#### Connectors (Sensor I/O connectors)

Blue

Black

DC



3

4

Power supply (0 V)

Output


### Dimensions

Note: All units are in millimeters unless otherwise stated.


#### E3FZ-Series

E3FZ-T


Emitter

















Stability indicator (green)





Connector models






#### E3FR Series


#### Pre-wired models

Connector models


#### E3FR-TD1H 2M



E3FR-R□1H 2M E3FR-LS□1H 2M




E3FR-D 2 2M



#### Accessories



Material: ABS base,



E38-R49






6.5


-~ 2-3

Material: ABS base, acrylic surface

E39-EL8







E39-EL9

stainless steel

(can be attached to dia 12 mm mounting rod)

Material:

stainless steel

Snap mount tool






Material:







ABS

### Safety precautions

### \land Warning

This product is not designed or rated for directly or indirectly ensuring safety of persons. Do not use it for such a purpose.

#### 

Do not use the product with voltage in excess of the rated voltage. Excess voltage may result in malfunction or fire.



Never use the product with an AC power supply. Otherwise, explostion may result.



When cleaning the product, do not apply a high-pressure spray of water to one part of the product. Otherwise, parts may become damaged and the degree of protection may be degraded.





#### Precautions for Safe Use

The following precautions must be observed to ensure safe operation of the Sensor.

#### **Operating Environment**

Do not use the Sensor in an environment where explosive or flammable gas is present.

#### **Connecting Connectors**

Be sure to hold the connector cover when inserting or removing the connector. Be sure to tighten the connector lock by hand; do not use pliers or other tools. If the tightening is insufficient, the degree of protection will not be maintained and the Sensor may become loose due to vibration. The appropriate tightening torque is 0.39 to 0.49 N·m for M12 connectors.

#### Load

Do not use a load that exceeds the rated load.

Rotation Torque for Sensitivity Adjustment

Adjust with a torque of 0.05 N·m or less. Environements with Cleaners and Disinfectants

#### (e.g., Food Processing Lines)

Do not use the Sensor in environments subject to cleaners and disifectants. They may reduce the degree of protection.

Do not attempt to disassemble, repair, or modify the Sensor. Outdoor Use

Do not use the Sensor in locations subject to direct sunlight. Cleaning

Do not use thinner, alcohol, or other organic solvents. Otherwise, the optical properties and degree of protection may be degraded. Surface Temperature

Burn injury may occur. The Sensor surface temperature rises depending on application conditions, such as the surrounding temperature and the power supply voltage. Use caution when operating or washing the Sensor.

#### Precautions for Correct Use

Do not use the Sensor in any atmosphere or environment that exceeds the ratings.

#### Do not install the Sensor in the following locations.

- (1) Locations subject to direct sunlight
- (2) Locations subject to condensation due to high humidity
- (3) Locations subject to corrosive gas
- (4) Locations where the Sensor may receive direct vibration or shock

#### **Connecting and Mounting**

- (1) The maximum power supply voltage is 30 VDC. Before turning the power ON, make sure that the power supply voltage does not exceed the maximum voltage.
- (2) Laying Sensor wiring in the same conduit or duct as high-voltage wires or power lines may result in malfunction or damage due to induction. As a general rule, wire the Sensor in a separate conduit or use shielded cable.
- (3) Use an extension cable with a minimum thickness of 0.3 mm<sup>2</sup> and less than 100 m long.
- (4) Do not pull on the cable with excessive force.
- (5) Pounding the Photoelectric Sensor with a hammer or other tool during mounting will impair water resistance.
- (6) Mount the Sensor either using the bracket (sold separately) or on a flat surface.
- (7) Be sure to turn OFF the power supply before inserting or removing the connector.

#### Cleaning

Never use thinner or other solvents. Otherwise, the Sensor surface may be dissolved.

#### **Power Supply**

If a commercial switching regulator is used, ground the FG (frame ground) terminal.

#### Power Supply Reset Time

The Sensor will be able to detect objects 100 ms after the power supply is tuned ON. Start using the Sensor 100 ms or more after turning ON the power supply. If the load and the Sensor are connected to separate power supplies, be sure to turn ON the Sensor first.

#### Turning OFF the Power Supply

Output pulses may be generated even when the power supply is OFF. Therefore, it is recommended to first turn OFF the power supply for the load or the load line.

#### Load Short-circuit Protection

This Sensor is equipped with load short-circuit protection, but be sure to not short circuit the load. Be sure to not use an output current flow that exceeds the rated current. If a load short circuit occurs, the output will turn OFF, so check the wiring before turning ON the power supply again. The short-circuit protection circuit will be reset. The load short-circuit protection will operate when the current flow reaches 1.8 times the rated load current. When using a capacitive load, use an inrush current of 1.8 times the rated load current or higher.

#### Water Resistance

Do not use the Sensor in water, rainfall, or outdoors.

## Terms and Conditions of Sale

- 1. Offer; Acceptance. These terms and conditions (these "Terms") are deemed part of all quotes, agreements, purchase orders, acknowledgments, price lists, catalogs, manuals, brochures and other documents, whether electronic or in catalogs, manuals, brochures and other documents, whether electronic or in writing, relating to the sale of products or services (collectively, the "Products") by Omron Electronics LLC and its subsidiary companies ("Omron"). Omron objects to any terms or conditions proposed in Buyer's purchase order or other documents which are inconsistent with, or in addition to, these Terms. Prices: Payment Terms, All prices stated are current, subject to change without notice by Omron. Omron reserves the right to increase or decrease prices on any unshipped portions of outstanding orders. Payments for Products are due net 30 days unless otherwise stated in the invoice. Discounts, Cash discounts, if any, will apply only on the net amount of invoices sent to Buyer after deducting transportation charges, taxes and duties, and will be allowed only if (i) the invoice is paid according to Omron's payment terms and (ii) Buyer has no past due amounts.
- 2
- 3.
- and (ii) Buyer has no past due amounts. Interest. Omron, at its option, may charge Buyer 1-1/2% interest per month or the maximum legal rate, whichever is less, on any balance not paid within the stated terms.
- Orders. Omron will accept no order less than \$200 net billing. Governmental Approvals. Buyer shall be responsible for, and shall bear all 6 costs involved in, obtaining any government approvals required for the impor-tation or sale of the Products.
- Taxes. All taxes, duties and other governmental charges (other than general real property and income taxes), including any interest or penalties thereon, imposed directly or indirectly on Omron or required to be collected directly or 7. indirectly by Omron for the manufacture, production, sale, delivery, importa-tion, consumption or use of the Products sold hereunder (including customs duties and sales, excise, use, turnover and license taxes) shall be charged to and remitted by Buyer to Omron. <u>Financial.</u> If the financial position of Buyer at any time becomes unsatisfactory
- 8. <u>Einancial</u> If the financial position of Buyer at any time becomes unsatisfactory to Omron, Omron reserves the right to stop shipments or require satisfactory security or payment in advance. If Buyer fails to make payment or otherwise comply with these Terms or any related agreement, Omron may (without liabil-ity and in addition to other remedies) cancel any unshipped portion of Prod-ucts sold hereunder and stop any Products in transit until Buyer pays all amounts, including amounts payable hereunder, whether or not then due, which are owing to it by Buyer. Buyer shall in any event remain liable for all unpaid accounts unpaid accounts.
- <u>Cancellation</u>, <u>Etc.</u> Orders are not subject to rescheduling or cancellation unless Buyer indemnifies Omron against all related costs or expenses.
   <u>Force Majeure</u>. Omron shall not be liable for any delay or failure in delivery
- Force majeure. Other shall not be lable for any delay or lating in delivery resulting from causes beyond its control, including earthquakes, fires, floods, strikes or other labor disputes, shortage of labor or materials, accidents to machinery, acts of sabotage, riots, delay in or lack of transportation or the requirements of any government authority.
   Shipping: Delivery. Unless otherwise expressly agreed in writing by Omron: a. Shipments shall be by a carrier selected by Omron; Omron will not drop ship expert in "break down" situations.
- except in "break down" situations. b. Such carrier shall act as the agent of Buyer and delivery to such carrier shall
  - constitute delivery to Buyer; c. All sales and shipments of Products shall be FOB shipping point (unless oth-
- c. All sales and shipments of Products shall be FOB shipping point (unless otherwise stated in writing by Omron), at which point title and risk of loss shall pass from Omron to Buyer; provided that Omron shall retain a security interest in the Products until the full purchase price is paid;
  d. Delivery and shipping dates are estimates only; and
  e. Omron will package Products as it deems proper for protection against normal handling and extra charges apply to special conditions.
  12. <u>Claims</u>. Any claim by Buyer against Omron for shortage or damage to the Products occurring before delivery to the carrier must be presented in writing to Omron within 30 days of receipt of shipment and include the original transportation bill signed by the carrier received the Products
- portation bill signed by the carrier noting that the carrier received the Products from Omron in the condition claimed.
- <u>Warranties</u>. (a) <u>Exclusive Warranty</u>. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed 13 (b) <u>Limitations</u>. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABIL-

### Certain Precautions on Specifications and Use

- Suitability of Use. Omron Companies shall not be responsible for conformity 1. with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request. Omron will provide application to use of the Froduct. At Buyer's application of use of the product applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Prod-uct in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. the particular Product with respect to Buyers application, product or system. Buyer shall take application responsibility in all cases but the following is a non-exhaustive list of applications for which particular attention must be given: (i) Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this document. (ii) Use in consumer products or any use in significant quantities. (iii) Energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equip-ment and installicitors cubications of the consumer to construct the construction.

inent, and installations subject to separate industry or government regulations. (iv) Systems, machines and equipment that could present a risk to life or prop erty. Please know and observe all prohibitions of use applicable to this Prod-

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO

ITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or oth-erwise of any intellectual property right. (c) <u>Buyer Remedy</u>. Omron's sole obli-gation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsi-ble for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were prop-erly handled, stored, installed and maintained and not subject to contamina-tion, abuse, misuse or inappropriate modification. Return of any Products by tion, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Compa-nies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty. See http://www.omron247.com or contact your Omron representative for published information.

- Iished information.
  Limitation on Liability: Etc. OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY. Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted. 14
- Indemnities. Buyer shall indemnify and hold harmless Omron Companies and their employees from and against all liabilities, losses, claims, costs and expenses (including attorney's fees and expenses) related to any claim, inves-tigation, litigation or proceeding (whether or not Omron is a party) which arises 15 or is alleged to arise from Buyer's acts or omissions under these Terms or in any way with respect to the Products. Without limiting the foregoing, Buyer (at its own expense) shall indemnify and hold harmless Omron and defend or set-tle any action brought against such Companies to the extent based on a claim that any Product made to Buyer specifications infringed intellectual property rights of another party.
- rights of another party. <u>Property: Confidentiality.</u> Any intellectual property in the Products is the exclu-sive property of Omron Companies and Buyer shall not attempt to duplicate it in any way without the written permission of Omron. Notwithstanding any charges to Buyer for engineering or tooling, all engineering and tooling shall remain the exclusive property of Omron. All information and materials supplied by Omron to Buyer relating to the Products are confidential and proprietary, and Buyer shall limit distribution thereof to its trusted employees and strictly provent disclosure to any third party. 16
- 17
- "forbidden" or other proscribed persons; and (ii) disclosure to non-citizens of regulated technology or information. <u>Miscellaneous</u>. (a) <u>Waiver</u>. No failure or delay by Omron in exercising any right and no course of dealing between Buyer and Omron shall operate as a waiver of rights by Omron. (b) <u>Assignment</u>. Buyer may not assign its rights hereunder without Omron's written consent. (c) <u>Law</u>. These Terms are governed by the law of the jurisdiction of the home office of the Omron company from which Buyer is purchasing the Products (without regard to conflict of law principles). (d) <u>Amendment</u>. These Terms constitute the entire agreement between Buyer and Omron relating to the Products, and no provision may be changed or waived unless in writing signed by the parties. (e) Severability. If any provi-18 or waived unless in writing signed by the parties. (e) <u>Severability</u>. If any provision hereof is rendered ineffective or invalid, such provision shall not invalidate any other provision. (f) Setoff, Buyer shall have no right to set off any amounts against the amount owing in respect of this invoice. (g) <u>Definitions</u>. As used herein, "<u>including</u>" means "including without limitation"; and "<u>Omron Compa-</u> nies" (or similar words) mean Omron Corporation and any direct or indirect subsidiary or affiliate thereof.

ADDRESS THE RISKS, AND THAT THE OMRON'S PRODUCT IS PROP-ERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

- Programmable Products. Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof. <u>Performance Data</u>. Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitabil-ity and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application require-2 3 ments. Actual performance is subject to the Omron's Warranty and Limitations of Liability.
- Change in Specifications. Product specifications and accessories may be 4 Change in specifications. Product specifications and accessions may be changed at any time based on improvements and other reasons. It is our prac-tice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifica-tions of the Product may be changed without any notice. When in doubt, spe-cial part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual creating of purphased Product to confirm actual specifications of purchased Product. Errors and Omissions. Information presented by Omron Companies has been
- 5 checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.



OMRON INDUSTRIAL AUTOMATION • THE AMERICAS HEADQUARTERS • Schaumburg, IL USA • 847.843.7900 • 800.556.6766 • www.omron247.com

**OMRON CANADA, INC. • HEAD OFFICE** Toronto, ON, Canada • 416.286.6465 • 866.986.6766 • www.omron247.com

OMRON ELECTRONICS DE MEXICO • HEAD OFFICE México DF • 52.55.59.01.43.00 • 001.800.556.6766 • mela@omron.com

OMRON ELECTRONICS DE MEXICO • SALES OFFICE Apodaca, N.L. • 52.81.11.56.99.20 • 001.800.556.6766 • mela@omron.com

OMRON ELETRÔNICA DO BRASIL LTDA • HEAD OFFICE São Paulo, SP, Brasil • 55.11.2101.6300 • www.omron.com.br OMRON ARGENTINA • SALES OFFICE Cono Sur • 54.11.4783.5300

**OMRON CHILE • SALES OFFICE** Santiago • 56.9.9917.3920

OTHER OMRON LATIN AMERICA SALES 54.11.4783.5300

OMRON EUROPE B.V. • Wegalaan 67-69, NL-2132 JD, Hoofddorp, The Netherlands. • Tel: +31 (0) 23 568 13 00 • Fax: +31 (0) 23 568 13 88 • www.industrial.omron.eu

Authorized Distributor:

#### Automation Systems

- Programmable logic controllers (PLC) Human machine interfaces (HMI) Remote I/O
- Industrial PC's Software

#### Motion & Drives

• Motion controllers • Servo systems • AC drives

#### **Control Components**

- Temperature controllers Power supplies Timers Counters Programmable relays
- Digital panel indicators Electromechanical relays Monitoring products Solid-state relays
- Limit switches Pushbutton switches Low voltage switch gear

#### Sensing & Safety

- Photoelectric sensors Inductive sensors Capacitive & pressure sensors
- Cable connectors Displacement & width-measuring sensors Vision systems
- Safety networks Safety sensors Safety units/relay units Safety door/guard lock switches

